

Extremum-seeking control for steady-state performance optimization of nonlinear plants with time-varying steady-state outputs^{*}

Leroy Hazeleger[†], Mark Haring[‡], and Nathan van de Wouw^{††}

Abstract—Extremum-seeking control is a useful tool for the steady-state performance optimization of plants for which the dynamics and disturbance situation can be unknown. The case when steady-state plant outputs are constant received a lot of attention, however, in many applications time-varying outputs characterize plant performance. As a result, no static parameter-to-steady-state performance map can be obtained. In this work, an extremum-seeking control method is proposed that uses a so-called dynamic cost function to cope with these time-varying outputs. We show that, under appropriate conditions, the solutions of the extremum-seeking control scheme are uniformly ultimately bounded in view of bounded and time-varying external disturbances, and the region of convergence towards the optimal tunable plant parameters can be made arbitrarily small. Moreover, its working principle is illustrated by means of the performance optimal tuning of a variable-gain controller for a motion control application.

I. INTRODUCTION

Extremum-seeking control, categorized as being an adaptive control approach, is a data-driven and, in essence, model-free control technique for optimizing the steady-state performance of a stable or stabilized plant in real-time, by automated adaptation of tunable plant parameters [1], [2]. Due to its model-free character, extremum-seeking control is a particularly useful tool in applications where only little knowledge of the plant dynamics is available and, as such, has been applied in many different engineering domains [3], [4], [5], [15]. In addition, practical applications are usually subject to external disturbances which are in general not known a priori, which further emphasizes the power of extremum-seeking control as a model-free technique. In fact, the (performance optimal) steady-state output of the plant is often not analytically known due to the lack of plant and disturbance knowledge, and can only be assessed through output measurements. An extremum-seeking controller is able to exploit these measured plant outputs irrespectively

of the availability of plant and disturbance knowledge, and subsequently uses the measured outputs to steer the tunable plant parameters to their performance optimal values, thereby achieving optimal steady-state performance.

The general requirement for the plant to be optimized is the existence of a (unknown) static parameter-to-steady-state performance map, i.e., a *static* input-to-output map, whose extremum corresponds to the optimal steady-state (equilibrium) plant performance [1], [6], [2]. In many applications, such a static input-to-output map, where steady-state performance is characterized by an equilibrium solution, does not exist because performance is related to *time-varying* plant behavior. This time-varying behavior can originate for example from reference tracking or disturbance attenuation problems, which are encountered, for example, in industrial motion systems, such as, pick-and-place systems, electron microscopes, and wafer scanning systems [12].

In [8], an extremum-seeking controller is developed for dynamical plants that do not exhibit equilibrium solutions but instead have limit cycle behavior, which can be reduced in size by some tunable plant parameter. The authors added a detector that captures the amplitude of the limit cycle, which is assumed to be sinusoidal. Considering the plant and the detector as one extended plant with the plant parameter as input and the amplitude of the limit cycle as output, a constant steady-state relation between the input and output is obtained. The work in [8] has been applied, e.g., in the suppression of subsonic cavity flow resonances [13], and automatic mode matching in vibrating gyroscopes [14].

In [9], an extremum-seeking control scheme is designed for steady-state output optimization of a class of differentially flat periodic nonlinear systems. Using the flatness property of the dynamics, a period of the periodic steady-state output of the plant is computed. Extremum-seeking control is then used to optimize the computed steady-state output in real-time, based on a user-defined cost functional evaluated over that periodic steady-state output. In [7], a similar approach as in [9] is pursued for the steady-state output optimization of periodic Hamiltonian systems.

In [10], an extremum-seeking scheme is proposed for the optimization of general nonlinear plants with periodic steady-state outputs. Knowing the period time of the periodic steady-state output, a cost function is designed that links the periodic output of the plant to a performance measure, such as, e.g., an \mathcal{L}^p -norm of the error response computed over the periodic time interval. Considering the plant and the cost function as one extended plant, a constant steady-state relation between the input and output is obtained. In [15], this method was experimentally demonstrated for the adaptive design of variable-gain controllers for a motion

^{*}This research is part of the research programme High Tech Systems and Materials (HTSM), which is supported by NWO domain Applied and Engineering Sciences and partly funded by the Ministry of Economic Affairs

[†]The work of Mark Haring is sponsored by the Research Council of Norway with project number 250725, and through the Centres of Excellence funding scheme, project number 223254 - Centre for Autonomous Marine Operations and Systems (NTNU-AMOS)

[†] L. Hazeleger is with the Eindhoven University of Technology, Department of Mechanical Engineering, P.O. Box 513, Eindhoven 5600 MB, The Netherlands l.hazeleger@tue.nl

[‡] M.A.M. Haring is with the Norwegian University of Science and Technology, Department of Engineering Cybernetics, Trondheim 7491, Norway mark.haring@ntnu.no

^{††} N. van de Wouw is with the Department of Mechanical Engineering, Eindhoven University of Technology, Eindhoven 5600 MB, The Netherlands, also with the Department of Civil, Environmental and Geo-Engineering, University of Minnesota, Minneapolis, MN 55455 USA, and also with the Delft Center for Systems and Control, Delft University of Technology, Delft 2628 CD, The Netherlands n.v.d.wouw@tue.nl

control application.

In many (industrial) applications, the steady-state response characterizing system performance is time-varying, and periodicity of the steady-state response is not evident due to the fact that responses can be induced by complex time-varying disturbances and reference signals. In such generic cases, a static input-to-output performance map may not be readily defined as in the periodic cases in [15], [8], and [10].

The main contribution of this work is as follows. First, we propose a local extremum-seeking method for steady-state performance optimization of general nonlinear plants with time-varying steady-state outputs. The proposed extremum-seeking control method includes a so-called *dynamic cost function* in terms of the time-varying output response, allowing for the characterization of a static input-to-output map. Second, under appropriate conditions, we prove that the solutions of the closed-loop extremum-seeking control scheme are uniformly ultimately bounded in view of bounded, time-varying disturbances. Moreover, we show that the region of convergence towards the optimal tunable plant parameters can be made arbitrarily small. Third, an illustrative example is presented in which performance is optimized of a variable-gain controlled motion system exhibiting time-varying outputs.

The paper is organized as follows. Section II presents the problem formulation. Section III gives the extremum-seeking controller. In Section IV the stability result is stated, and in Section V the illustrative example is provided.

II. EXTREMUM-SEEKING CONTROL PROBLEM FOR TIME-VARYING OUTPUTS

Consider the following multi-input-multi-output nonlinear plant:

$$\Sigma_p : \begin{cases} \dot{\mathbf{x}}(t) = \mathbf{f}(\mathbf{x}(t), \mathbf{u}(t), \mathbf{w}(t)) \\ \mathbf{e}(t) = \mathbf{g}(\mathbf{x}(t), \mathbf{u}(t), \mathbf{w}(t)), \end{cases} \quad (1)$$

where $\mathbf{x} \in \mathbb{R}^{n_x}$ is the state of the plant, $\mathbf{u} \in \mathbb{R}^{n_u}$ is the input of the plant, $\mathbf{e} \in \mathbb{R}^{n_e}$ is the output of the plant, $\mathbf{w} \in \mathbb{R}^{n_w}$ are disturbances, and $t \in \mathbb{R}$ is time. In the context of extremum-seeking control, the input \mathbf{u} is a vector of tunable plant parameters, the output \mathbf{e} is a vector of measured performance variables, and \mathbf{w} are (time-varying) disturbances, for which we adopt the following assumption.

Assumption 1: The disturbances $\mathbf{w}(t)$ are piecewise continuous, defined and bounded on $t \in \mathbb{R}$. Moreover, there exists a constant $\rho_w \in \mathbb{R}_{>0}$ such that $\mathbf{w}(t) \in \mathcal{W}$ for all $t \in \mathbb{R}$, with $\mathcal{W} = \{\mathbf{w} \in \mathbb{R}^{n_w} : \|\mathbf{w}\| \leq \rho_w\}$.

In addition, we adopt the following assumption on the plant.

Assumption 2: The plant Σ_p in (1) is globally exponentially convergent¹ for all constant inputs $\mathbf{u} \in \mathcal{U}$, where $\mathcal{U} \subset \mathbb{R}^{n_u}$ is a compact set.

Remark 1: Assumption 2 guarantees that, for any constant $\mathbf{u} \in \mathcal{U}$ and any $\mathbf{w}(t) \in \mathcal{W}$, there exists a unique globally exponentially stable (time-varying) steady-state solution. This assumption is the time-varying analogue of the common assumption in extremum-seeking literature on the plant exhibiting globally asymptotically stable equilibria. In many (nonlinear) control problems, for example tracking,

synchronization, observer design and output regulation problems, the convergent system property that all solutions of a closed-loop system converges to some steady-state solution and thus "forget" their initial condition plays an important role. Moreover, this property is immediate for asymptotically stable linear time-invariant systems with inputs.

From Assumptions 1 and 2, it follows that for all constant inputs $\mathbf{u} \in \mathcal{U}$ and all disturbances $\mathbf{w}(t) \in \mathcal{W}$ there exists a unique steady-state solution of the plant Σ_p , which is defined and bounded on $t \in \mathbb{R}$ and globally exponentially stable (GES). The steady-state solution is denoted by $\bar{\mathbf{x}}_w(t, \mathbf{u})$, emphasizing the dependency on time-varying disturbances $\mathbf{w}(t)$ and constant inputs \mathbf{u} , and satisfies

$$\dot{\bar{\mathbf{x}}}_w(t, \mathbf{u}) = \mathbf{f}(\bar{\mathbf{x}}_w(t, \mathbf{u}), \mathbf{u}, \mathbf{w}(t)). \quad (2)$$

In addition, we adopt the following assumption.

Assumption 3: The steady-state solution $\bar{\mathbf{x}}_w(t, \mathbf{u})$ is twice continuously differentiable in \mathbf{u} and satisfies

$$\left\| \frac{\partial \bar{\mathbf{x}}_w}{\partial \mathbf{u}}(t, \mathbf{u}) \right\| \leq L_{xu}, \quad (3)$$

for all $t \in \mathbb{R}$, all $\mathbf{u} \in \mathcal{U}$, and some constant $L_{xu} \in \mathbb{R}_{>0}$.

Furthermore, it follows from Assumption 2 that there exists a unique steady-state output of the plant Σ_p in (1), denoted by $\bar{\mathbf{e}}_w(t, \mathbf{u})$, which is given by $\bar{\mathbf{e}}_w(t, \mathbf{u}) = \mathbf{g}(\bar{\mathbf{x}}_w(t, \mathbf{u}), \mathbf{u}, \mathbf{w}(t))$. It is the task of the designer to define a bounded cost function, denoted by Z , that quantifies the performance of interest for the plant under study. Then, the corresponding measured plant performance is given by

$$y(t) = Z(\mathbf{e}(t), \mathbf{u}(t)), \quad y \in \mathbb{R}. \quad (4)$$

For all constant inputs $\mathbf{u} \in \mathcal{U}$ and all (time-varying) disturbances $\mathbf{w}(t) \in \mathcal{W}$, the steady-state plant performance $\bar{y}_w(t, \mathbf{u})$ is given by $\bar{y}_w(t, \mathbf{u}) = Z(\mathbf{g}(\bar{\mathbf{x}}_w(t, \mathbf{u}), \mathbf{u}, \mathbf{w}(t)), \mathbf{u})$. Our aim is to find the constant input values \mathbf{u} that minimize the measured steady-state plant performance \bar{y}_w , yielding the optimization of the steady-state plant output $\bar{\mathbf{e}}_w$. In the context of extremum-seeking control, ideally the measured steady-state plant performance \bar{y}_w is constant for constant inputs \mathbf{u} ; this forms one of the basic assumptions in the extremum-seeking literature [1], [6]. However, due to the time-varying nature of the disturbances $\mathbf{w}(t)$ in (1), in general, the measured steady-state plant performance \bar{y}_w is time-varying in nature (also for constant \mathbf{u}).

To deal with time-varying plant outputs, consider the series connection of the plant Σ_p as in (1), the cost function Z as in (4), and additionally a filter, denoted by Σ_f , which reads

$$\Sigma_f : \begin{cases} \dot{\mathbf{z}}(t) = \alpha_z \mathbf{h}(\mathbf{z}(t), y(t)) \\ l(t) = k(\mathbf{z}(t)), \end{cases} \quad (5)$$

where $\alpha_z \in \mathbb{R}_{>0}$ is a tuning parameter, $\mathbf{z} \in \mathbb{R}^{n_z}$ is the state of the filter, $y \in \mathbb{R}$ is the input of the filter defined by (4), and $l \in \mathbb{R}$ is the output of the filter. Intuitively, the filter Σ_f acts as an averaging operator on $y(t)$, utilized to quantify performance of the plant similar to the use of exponentially weighting filters [8], [14]. Basically, if we tune α_z small, the solution of $\mathbf{z}(t)$ will vary "slowly" in time, i.e., the output of the filter $l(t)$ will be quasi-constant and determined predominantly by the average of $y(t)$.

¹For definitions of convergent systems the reader is referred to Section 2.2 in [16].

The series connection of the cost function Z in (4) and the filter Σ_f in (5), we call the *dynamic cost function*. We adopt the following assumption on the dynamic cost function.

Assumption 4: The dynamic cost function consisting of the cascade of Z and Σ_f , given by (4) and (5), respectively, is exponentially input-to-state convergent² for all constant inputs $\mathbf{u} \in \mathcal{U}$ and all $\alpha_z \in \mathbb{R}_{>0}$.

The series connection of the nonlinear plant Σ_p in (1), the user-defined cost function Z in (4), and the to-be-designed filter Σ_f in (5) is referred to as the extended plant Σ and is schematically depicted in Fig. 1. The dynamics of the extended plant is given by

$$\Sigma : \begin{cases} \dot{\mathbf{x}}(t) = \mathbf{f}(\mathbf{x}(t), \mathbf{u}(t), \mathbf{w}(t)) \\ \dot{\mathbf{z}}(t) = \alpha_z \mathbf{h}(\mathbf{z}(t), Z(\mathbf{g}(\mathbf{x}(t), \mathbf{u}(t), \mathbf{w}(t))), \mathbf{u}(t)) \\ l(t) = k(\mathbf{z}(t)). \end{cases} \quad (6)$$

We adopt the following assumption on the extended plant regarding the smoothness of functions.

Assumption 5: Functions \mathbf{f} and \mathbf{g} in (1) are twice continuously differentiable in \mathbf{x} and \mathbf{u} and continuous in \mathbf{w} . Function Z in (4) is twice continuously differentiable with respect to both arguments. Functions \mathbf{h} and k in (5) are twice continuously differentiable with respect to all arguments.

Remark 2: The smoothness of the functions \mathbf{f} and \mathbf{g} in Assumption 5 is a common assumption in the extremum-seeking literature, see, e.g., [1], [6]. The smoothness of the functions Z , \mathbf{h} , and k can easily be satisfied by design. By similar arguments as in the proof of Property 2.27 in [16], we can conclude from Assumptions 2 and 4 that the extended plant Σ in (6) is globally exponentially convergent for all constant inputs $\mathbf{u} \in \mathcal{U}$ and disturbances $\mathbf{w}(t) \in \mathcal{W}$. As such, there exists a unique steady-state solution of Σ_f , induced by the extended plant, which is defined and bounded on $t \in \mathbb{R}$ and GES. This steady-state solution is denoted by $\bar{\mathbf{z}}_w(t, \mathbf{u}, \alpha_z)$, emphasizing the dependency on time-varying disturbances $\mathbf{w}(t)$, constant inputs \mathbf{u} , and the tunable parameter α_z , and satisfies

$$\dot{\bar{\mathbf{z}}}_w(t, \mathbf{u}, \alpha_z) = \alpha_z \mathbf{h}(\bar{\mathbf{z}}_w(t, \mathbf{u}, \alpha_z), \bar{y}_w(t, \mathbf{u})). \quad (7)$$

In addition, we adopt the following assumption.

Assumption 6: There exists a twice continuously differentiable function $\mathbf{q}_w : \mathbb{R}^{n_u} \rightarrow \mathbb{R}^{n_z}$, referred to as the constant performance cost, such that

$$\lim_{\alpha_z \rightarrow 0} \bar{\mathbf{z}}_w(t, \mathbf{u}, \alpha_z) = \mathbf{q}_w(\mathbf{u}), \quad (8)$$

for all $t \in \mathbb{R}$ and all $\mathbf{u} \in \mathcal{U}$ and $\mathbf{w}(t) \in \mathcal{W}$. Moreover, there exist constants $\delta_w \in \mathbb{R}_{\geq 0}$, related to the disturbances $\mathbf{w}(t)$ and the extended plant Σ , and $L_{z1} \in \mathbb{R}_{>0}$, such that

$$\|\bar{\mathbf{z}}_w(t, \mathbf{u}, \alpha_z) - \mathbf{q}_w(\mathbf{u})\| \leq \alpha_z \delta_w, \quad (9)$$

and

$$\left\| \frac{\partial \bar{\mathbf{z}}_w}{\partial \mathbf{u}}(t, \mathbf{u}, \alpha_z) - \frac{d\mathbf{q}_w}{d\mathbf{u}}(\mathbf{u}) \right\| \leq \alpha_z L_{z1}, \quad (10)$$

for all $t \in \mathbb{R}$, all $\mathbf{u} \in \mathcal{U}$ and all $0 < \alpha_z \leq \epsilon_z$ for some $\epsilon_z \in \mathbb{R}_{>0}$.

Hence, by Assumption 6, under steady-state conditions of the plant Σ_p , the cost function Z , the filter Σ_f , the limit

²For the definition of input-to-state convergent the reader is referred to Definition 2.18 in [16].




Fig. 1. The extended plant Σ , i.e., series connection of the nonlinear plant Σ_p , the user-defined cost function Z , and the to-be-designed filter Σ_f .

$\alpha_z \rightarrow 0$, and for constant inputs $\mathbf{u} \in \mathcal{U}$, we have that the parameter-to-steady-state performance cost of the plant can be characterized by the static input-to-output map

$$F_w(\mathbf{u}) := k(\mathbf{q}_w(\mathbf{u})), \quad \forall \mathbf{u} \in \mathcal{U}. \quad (11)$$

We refer to the map F_w as the objective function. To minimize the steady-state plant performance \bar{y}_w , we aim to find the plant parameter values for which the objective function in (11) is minimal. We further assume that the dynamic cost function $Z + \Sigma_f$ is designed such that there exists a unique minimum of the objective function F_w on the compact set \mathcal{U} for any (time-varying) disturbance $\mathbf{w}(t) \in \mathcal{W}$ satisfying Assumption 1, where the minimum of the map F_w corresponds to the optimal plant performance. This assumption is formulated as follows.

Assumption 7: The objective function $F_w : \mathbb{R}^{n_u} \rightarrow \mathbb{R}$ in (11) is twice continuously differentiable and exhibits a unique minimum in the interior of the compact set \mathcal{U} . Let the corresponding optimal input \mathbf{u}^* be defined as

$$\mathbf{u}^* = \arg \min_{\mathbf{u} \in \mathcal{U}} F_w(\mathbf{u}). \quad (12)$$

Furthermore, there exists a constant $L_{F1} \in \mathbb{R}_{>0}$ such that

$$\frac{dF_w}{d\mathbf{u}}(\mathbf{u})(\mathbf{u} - \mathbf{u}^*) \geq L_{F1} \|\mathbf{u} - \mathbf{u}^*\|^2, \quad \forall \mathbf{u} \in \mathcal{U}. \quad (13)$$

From Assumption 7, it follows that the vector of tunable plant parameters \mathbf{u} will converge to optimal input \mathbf{u}^* if we are able to design a controller that drives the tunable plant parameters \mathbf{u} in opposite direction of the gradient of the objective function in (11). However, since the steady-state solutions of the plant in (1) and the filter in (5) and the objective function F_w are unknown, we typically cannot design such a gradient-descent controller. Information of the objective function can only be obtained through measured outputs l of the extended plant in (6). The measured output differs from the objective function F_w in two ways; i) due to the dynamics of the plant in (1) and the filter in (5) not being in steady-state, and ii) due to the presence of (time-varying) disturbances $\mathbf{w}(t)$ and the design parameter α_z which, in the presence of time-varying disturbances $\mathbf{w}(t)$, is typically designed to be small, but still non-zero and positive. Nevertheless, we aim to steer the inputs \mathbf{u} to their performance optimizing values \mathbf{u}^* by using the measured extended plant output $l(t)$ as feedback to an extremum-seeking controller that is introduced in the next section.

III. EXTREMUM-SEEKING CONTROLLER

The controller design proposed here follows from the one in [11, Ch. 2]. In Section III-A, a dither signal design is presented, in Section III-B, a model of the input-to-output behavior of the plant is presented to be used as a basis for gradient estimation, in Section III-C, a least-squares observer to estimate the state of that model (and therewith the gradient) and a normalized optimizer to steer the plant parameters \mathbf{u} to the minimizer \mathbf{u}^* are presented, and, in

Section III-D, tuning guidelines are provided for the closed-loop system composed of the extended plant Σ in (6) and the extremum-seeking controller.

A. Dither signal

To estimate the gradient of the objective function and use this estimated gradient to drive \mathbf{u} towards \mathbf{u}^* by an optimizer, we define the following input signal:

$$\mathbf{u}(t) = \hat{\mathbf{u}}(t) + \alpha_\omega \boldsymbol{\omega}(t), \quad (14)$$

where $\alpha_\omega \boldsymbol{\omega}$ is a vector of perturbation signals with amplitude $\alpha_\omega \in \mathbb{R}_{>0}$, and $\hat{\mathbf{u}}$ is referred to as the nominal input to be generated by the extremum-seeking controller. The vector $\boldsymbol{\omega}$ is defined by $\boldsymbol{\omega}(t) = [\omega_1(t), \omega_2(t), \dots, \omega_{n_u}(t)]^\top$, with

$$\omega_i(t) = \begin{cases} \sin\left(\frac{i+1}{2}\eta_\omega t\right), & \text{if } i \text{ is odd,} \\ \cos\left(\frac{i}{2}\eta_\omega t\right), & \text{if } i \text{ is even,} \end{cases} \quad (15)$$

for $i = \{1, 2, \dots, n_u\}$, where $\eta_\omega \in \mathbb{R}_{>0}$ is a tuning parameter. The purpose of the perturbation signal is to provide sufficient excitation to accurately estimate the gradient of the objective function. The nominal plant parameters $\hat{\mathbf{u}}$ can be regarded as an estimate of the minimizer \mathbf{u}^* .

B. Model of input-to-output behavior of the extended plant

To obtain an estimate of the gradient of the objective function, we model the input-to-output behavior of the extended plant in (6), that is, from the nominal input $\hat{\mathbf{u}}$ to the measured output of the extended plant l , in a general form. Let the state of the model be given by

$$\mathbf{m}(t) = [F_w(\hat{\mathbf{u}}(t)) \quad \alpha_\omega \frac{dF_w}{d\mathbf{u}}(\hat{\mathbf{u}}(t))]^\top. \quad (16)$$

From Taylor's Theorem and (14), F_w can be written as

$$\begin{aligned} F_w(\mathbf{u}(t)) &= F_w(\hat{\mathbf{u}}(t)) + \alpha_\omega \frac{dF_w}{d\mathbf{u}}(\hat{\mathbf{u}}(t))\boldsymbol{\omega}(t) \\ &+ \alpha_\omega^2 \boldsymbol{\omega}^\top(t) \int_0^1 (1-\sigma) \frac{d^2 F_w}{d\mathbf{u}d\mathbf{u}^\top}(\hat{\mathbf{u}}(t) + \sigma \alpha_\omega \boldsymbol{\omega}(t)) d\sigma \boldsymbol{\omega}(t). \end{aligned} \quad (17)$$

The dynamics of the state in (16) is governed by

$$\begin{aligned} \dot{\mathbf{m}}(t) &= \mathbf{A}(t)\mathbf{m}(t) + \alpha_\omega^2 \mathbf{B}\mathbf{s}(t) \\ l(t) &= \mathbf{C}(t)\mathbf{m}(t) + \alpha_\omega^2 v(t) + r(t) + d(t), \end{aligned} \quad (18)$$

with the matrices \mathbf{A} , \mathbf{B} and \mathbf{C} defined as

$$\mathbf{A}(t) = \begin{bmatrix} 0 & \frac{\dot{\hat{\mathbf{u}}}(t)}{\alpha_\omega} \\ 0 & 0 \end{bmatrix}, \quad \mathbf{B} = \begin{bmatrix} 0 \\ \mathbf{I} \end{bmatrix}, \quad \mathbf{C}(t) = \begin{bmatrix} 1 & \boldsymbol{\omega}^\top(t) \end{bmatrix}, \quad (19)$$

and the signals \mathbf{s} , v , r , and d defined as

$$\begin{aligned} \mathbf{s}(t) &:= \frac{d^2 F_w}{d\mathbf{u}d\mathbf{u}^\top}(\hat{\mathbf{u}}(t)) \frac{\dot{\hat{\mathbf{u}}}(t)}{\alpha_\omega}, \\ v(t) &:= \boldsymbol{\omega}^\top(t) \int_0^1 (1-\sigma) \frac{d^2 F_w}{d\mathbf{u}d\mathbf{u}^\top}(\hat{\mathbf{u}}(t) + \sigma \alpha_\omega \boldsymbol{\omega}(t)) d\sigma \boldsymbol{\omega}(t), \\ r(t) &:= k(\mathbf{z}(t)) - k(\bar{\mathbf{z}}_w(t, \mathbf{u}, \alpha_z)), \\ d(t) &:= k(\bar{\mathbf{z}}_w(t, \mathbf{u}, \alpha_z)) - k(\mathbf{q}_w(\mathbf{u}(t))). \end{aligned} \quad (20)$$

The signals \mathbf{s} , v , r and d can be interpreted as unknown disturbances to the model. The influences of \mathbf{s} , v , r and d on the state and output of the model in (18) are small if i) $\hat{\mathbf{u}}$ is slowly time varying, if ii) α_ω is small, if iii) the states \mathbf{x} of the plant in (1) and the states \mathbf{z} of the filter in (5) are close to their steady-state values, and if iv) α_z is small.




Fig. 2. The closed-loop system composed of the extended plant Σ , the observer Σ_o , the optimizer Σ_r , and the dither signal $\alpha_\omega \boldsymbol{\omega}$.

The state \mathbf{m} in (16) contains an estimate of the gradient of the objective function, scaled by the perturbation amplitude α_ω . Hence, an estimate of the gradient of the objective function can be obtained from an estimate of the state \mathbf{m} . Based on this gradient estimate, an optimizer can steer the plant parameters \mathbf{u} to the minimizer \mathbf{u}^* . In the next section, a least-squares observer and an optimizer for this purpose are proposed.

C. Controller design

We introduce an extremum-seeking controller that is composed of a dither signal as in (14), a least-squares observer to estimate the state \mathbf{m} of the model in (18), and an optimizer that uses the estimate of the state \mathbf{m} of the observer, denoted by $\hat{\mathbf{m}}$, to steer the nominal plant inputs $\hat{\mathbf{u}}$ to their performance optimal values \mathbf{u}^* .

The least-squares observer, denoted by Σ_o , is given by

$$\Sigma_o : \begin{cases} \dot{\hat{\mathbf{m}}}(t) = (\mathbf{A}(t) - \eta_m \sigma_r \mathbf{Q}(t) \mathbf{D}^\top \mathbf{D}) \hat{\mathbf{m}}(t) \\ \quad + \eta_m \mathbf{Q}(t) \mathbf{C}^\top(t) (l(t) - \mathbf{C}(t) \hat{\mathbf{m}}(t)) \\ \dot{\mathbf{Q}}(t) = \eta_m \mathbf{Q}(t) + \mathbf{A}(t) \mathbf{Q}(t) + \mathbf{Q}(t) \mathbf{A}^\top(t) \\ \quad - \eta_m \mathbf{Q}(t) (\mathbf{C}^\top(t) \mathbf{C}(t) + \sigma_r \mathbf{D}^\top \mathbf{D}) \mathbf{Q}(t), \end{cases} \quad (21)$$

where $\mathbf{D} = [\mathbf{0} \quad \mathbf{I}]$, and $\eta_m, \sigma_r \in \mathbb{R}_{>0}$ are tuning parameters related to the observer, referred to as a forgetting factor and a regularization constant, respectively.

The optimizer, denoted by Σ_r , is given by

$$\Sigma_r : \quad \dot{\hat{\mathbf{u}}}(t) = -\lambda_u \frac{\eta_u \mathbf{D} \hat{\mathbf{m}}(t)}{\eta_u + \lambda_u \|\mathbf{D} \hat{\mathbf{m}}(t)\|}, \quad (22)$$

with $\lambda_u, \eta_u \in \mathbb{R}_{>0}$ being tuning parameters related to the optimizer. Normalization of the adaptation gain in (22) is done to prevent solutions of the closed-loop system of the extended plant and the extremum-seeking controller from having a finite escape time if the state estimate $\hat{\mathbf{m}}$ is inaccurate [11, Ch. 2]. The closed-loop system, composed of the extended plant Σ in (6), the observer Σ_o in (21), and the optimizer Σ_r in (22), is depicted in Fig. 2.

D. Tuning guidelines

For the closed-loop system to operate properly, we have design guidelines that guarantee time-scale separation:

- 1) The convergence of the solutions of the plant dynamics in (1) to its steady-state operation is assumed to be *fast*,
- 2) The tuning parameter α_z of the filter in (5) is chosen small such that the difference between the time-varying steady-state solution of the extended plant Σ and the performance cost is small (see Assumption 6), however sufficiently large such that convergence of solutions of the filter dynamics is on a *medium-to-fast* time scale,
- 3) The dither frequencies parameterized by η_ω are chosen slower than the filter dynamics to provide sufficient excitation, admitting a *medium* time-scale,

- 4) The observer should use a sufficiently long time history of the perturbation signals and measurement signal to be able to accurately extract the state of the model [11, Ch. 2]; the observer dynamics and its design parameter η_m should be associated with a *medium-to-slow* time scale compared to the dither signal,
- 5) The nominal plant parameters \hat{u} , induced by the optimizer, should be slowly time varying with respect to the observer by proper design of the design parameters λ_u and η_u , admitting a *slow* (optimizer) time-scale.

IV. STABILITY ANALYSIS

In this section, we will provide a stability result for the closed-loop system described in the previous sections. Due to the perturbation of the tunable parameter u , the optimizer state \hat{u} will in general converge to a region of the performance-optimal value u^* . The next result states conditions on tuning parameters and initial conditions under which the extremum-seeking scheme guarantees that \hat{u} converge to an arbitrarily small set around the optimum u^* .

Theorem 1: Under Assumptions 1-7, there exist (sufficiently small) constants $\epsilon_1, \dots, \epsilon_6 \in \mathbb{R}_{>0}$, and initial conditions $x(0) \in \mathcal{X}_0$, symmetric and positive-definite $Q(0) \in \mathcal{Q}_0$, $\hat{u}(0) \in \mathcal{U}_0$, $z(0) \in \mathcal{Z}_0$, and $\hat{m}(0) \in \mathcal{M}_0$, where $\mathcal{X}_0 \subset \mathbb{R}^{n_x}$, $\mathcal{U}_0 \subset \mathbb{R}^{n_u}$, $\mathcal{Q}_0 \subset \mathbb{R}^{n_u+1 \times n_u+1}$, $\mathcal{Z}_0 \subset \mathbb{R}^{n_z}$, $\mathcal{M}_0 \subset \mathbb{R}^{n_u+1}$ are compact sets, such that the solutions of the closed-loop system consisting of the extended plant in (6) and the extremum-seeking controller (consisting of the dither signal in (14), the observer Σ_o in (21), and the optimizer Σ_r in (22)) are uniformly bounded for all $\alpha_z, \alpha_\omega, \eta_u, \lambda_u, \eta_m, \eta_\omega \in \mathbb{R}_{>0}$ and all $\sigma_r \in \mathbb{R}_{\geq 0}$ that satisfy $\alpha_z \leq \epsilon_1$, $\eta_\omega \leq \alpha_z \epsilon_2$, $\eta_m \leq \eta_\omega \epsilon_3$, $\alpha_\omega \lambda_u \leq \eta_m \epsilon_4$, $\eta_u \leq \alpha_\omega \eta_m \epsilon_5$, and $\sigma_r \leq \epsilon_6$. Moreover, the solutions $\hat{u}(t)$ satisfy

$$\limsup_{t \rightarrow \infty} \|\hat{u}(t)\| \leq \max \left\{ \alpha_\omega c_1, \frac{\eta_\omega}{\alpha_z} c_2, \frac{\alpha_z \delta_w}{\alpha_\omega} c_3 \right\}, \quad (23)$$

for some constants $c_1, \dots, c_3 \in \mathbb{R}_{>0}$, with $\tilde{u}(t) = \hat{u}(t) - u^*$.

Proof of Theorem 1: The proof can be found in [18]. \square

Remark 3: Tuning guidelines. Under the conditions of Theorem 1, it follows that, if we are dealing with constant (or no) disturbances $w(t)$, i.e., $\delta_w = 0$, the optimizer state \hat{u} converges to an arbitrarily small region of the performance-optimal value u^* if the dither parameters α_ω and η_ω are chosen sufficiently small for an arbitrary bounded α_z . To make the region to which \hat{u} converges arbitrarily small in case we are dealing with time-varying disturbances $w(t)$, i.e., $\delta_w > 0$, see (23), we subsequently tune α_ω small to make the first term in the right-hand side of (23) arbitrarily small, tune α_z small to make the third term in the right-hand side of (23) arbitrarily small, and finally tune η_ω small to make the second term in the right-hand side of (23) arbitrarily small.

V. ILLUSTRATIVE EXAMPLE

To illustrate the extremum-seeking control approach proposed in Section II, we consider an industrial case study of steady-state performance optimization of a closed-loop variable-gain controlled (VGC) motion stage as also studied in [17]. In Section V-A, the VGC motion stage subject to time-varying disturbances is introduced, and to illustrate




Fig. 3. The closed-loop variable-gain control scheme.

its effectiveness, in Section V-B the proposed extremum-seeking controller is employed to optimize the steady-state performance of the VGC motion stage.

A. Variable-gain controlled motion stage

The variable-gain controller structure is shown in Fig. 3. The scheme consists of a plant P , representing the dynamics of a short-stroke wafer stage of a wafer scanner in z -direction, and a nominal linear controller C , having transfer functions $P(s)$ and $C(s)$, respectively, with $s \in \mathbb{C}$ being the Laplacian variable, (time-varying) force disturbances $f(t)$, a nonlinear control element $\varphi(\cdot)$, and a shaping filter $F(s)$. Furthermore, e denotes the tracking error. The nonlinearity $\varphi(e)$, representing the variable-gain element with e as input, is given by a dead-zone characteristic

$$\varphi(e) = \begin{cases} \alpha(e + \delta) & \text{if } e < -\delta, \\ 0 & \text{if } |e| \leq \delta, \\ \alpha(e - \delta) & \text{if } e > \delta, \end{cases} \quad (24)$$

where α and δ denote the additional gain and the dead-zone length, respectively. The plant admits the transfer function representation $P(s) = (m_1 s^2 + b s + k) / s^2 (m_1 m_2 s^2 + b(m_1 + m_2)s + k(m_1 + m_2))$, with the following numerical values: $m_1 = 5$ kg, $m_2 = 17.5$ kg, $k = 7.5 \cdot 10^7$ N/m, $b = 90$ Ns/m. The nominal, and stabilizing linear controller consists of a PID-controller C_{pid} , a second-order low-pass filter C_{lp} and a notch filter C_n , i.e. $C(s) = C_{pid}(s)C_{lp}(s)C_n(s)$. The filters are given by $C_{pid}(s) = (k_p(s^2 + (\omega_i + \omega_d)s + \omega_i \omega_d)) / (\omega_d s)$, where $k_p = 6.9 \cdot 10^6$ N/m, $\omega_d = 3.8 \cdot 10^2$ rad/s, and $\omega_i = 3.14 \cdot 10^2$ rad/s; $C_{lp}(s) = \omega_{lp}^2 / (s^2 + 2\beta_{lp}\omega_{lp}s + \omega_{lp}^2)$, where $\omega_{lp} = 3.04 \cdot 10^3$ rad/s, and $\beta_p = 0.08$; $C_n(s) = (s^2 + 2\beta_z\omega_zs + \omega_z^2) / (s^2 + 2\beta_p\omega_p s + \omega_p^2)$, where $\omega_z = 4.39 \cdot 10^3$ rad/s, $\omega_p = 5.03 \cdot 10^3$ rad/s, $\beta_z = 2.7 \cdot 10^{-3}$, and $\beta_p = 0.88$. The shaping filter $F(s)$ is given by $F(s) = (s^2 + 2\beta_{z,F}\omega_{z,F}s + \omega_{z,F}^2) / (s^2 + 2\beta_{p,F}\omega_{p,F}s + \omega_{p,F}^2)$, with $\omega_{z,F} = \omega_{p,F} = 2 \cdot 10^3$ rad/s, $\beta_{z,F} = 0.6$, $\beta_{p,F} = 4.8$.

The disturbance $f(t)$ consists of a low-frequency contribution induced by setpoint accelerations in the x - and y -direction of the wafer stage (see scaled acceleration profile in Fig. 4), and a high-frequency force disturbance, modelled as a signal containing multiple sinusoidal components with both random frequencies between 200-500 Hz and phases.

The variable-gain controlled motion system satisfies Assumption 2 if the additional gain is chosen as $\alpha < 4.34$ (Theorem 1, [17]). The dead-zone length δ turns out to be a stability invariant tunable plant parameter, however, the choice for δ does affect significantly the achievable tracking performance. As such, we propose to tune the dead-zone length δ in real-time by the extremum-seeking control scheme presented in Sections II and III to optimize tracking performance.

B. Optimization using extremum-seeking control

For the extremum-seeking control scheme as presented in Sections II and III, we choose the cost function as $Z(e(t)) =$




Fig. 4. Tracking error for the Fig. 5. Objective function F_w and low-gain, high-gain, and optimized minimization of the performance cost by adaptation of δ .

$\|e(t)\|^2$, and the filter Σ_f as a second-order low-pass filter admitting the following state-space formulation

$$\Sigma_f : \begin{cases} \dot{z}_1(t) = \alpha_z z_2(t) \\ \dot{z}_2(t) = \alpha_z (y(t) - 2\beta_z z_2(t) - z_1(t)) \\ l(t) = z_1(t), \end{cases} \quad (25)$$

which is of the form in (5). Furthermore, for $\alpha_z, \beta_z \in \mathbb{R}_{>0}$, Assumption 4 is satisfied. The objective function is depicted in Fig. 5. The parameters of the extremum-seeking controller are chosen as $\beta_z = \frac{1}{2}\sqrt{2}$, $\alpha_z = 2$, $\eta_\omega = 1$, $\alpha_\omega = 1 \cdot 10^{-9}$, $\eta_m = 0.75$, $\sigma_r = 1 \cdot 10^{-8}$, $\lambda_u = 2 \cdot 10^8$, and $\eta_u = 1$. The initial conditions are chosen as $z^\top(0) = [2.85 \cdot 10^{-15} \ 0]$, $\hat{m}^\top(0) = [2.85 \cdot 10^{-15} \ 0]$, $Q(0) = [\frac{1}{1+2\sigma_r} \ 0]$ and $\hat{\delta}(0) = 1 \cdot 10^{-7}$. The extremum-seeking controller is enabled at $t = 10$ seconds. Fig. 6 shows the dead-zone length δ and the measured performance cost $l(t)$ as a function of time, respectively. In here, results are shown for three cases; cases 1 and 2 in which two constant values for δ are used, namely $\delta = 2 \cdot 10^{-7}$ and $\delta = 0$, associated with a low-gain and high-gain linear controller, respectively, and case 3 in which δ is tuned by an extremum-seeking controller. It can be seen that the plant parameter δ and the corresponding performance cost l converges to the performance optimal region, as illustrated in Fig. 5. Fig. 4 shows the measured tracking error for the low-gain, high-gain, and optimally tuned variable-gain controller.

Remark 4: The use of a dead-zone nonlinearity as presented in (24) actually violates Assumption 5. Although it is possible to define a sufficiently smooth nonlinearity $\varphi(\cdot)$ close to the dead-zone, for ease of implementation and the fact that the conclusions with respect to convergence are similar, we use the non-smooth nonlinearity as in (24).

VI. CONCLUSIONS

In this work, we have introduced a local extremum-seeking control method for steady-state performance optimization of general nonlinear plants with time-varying steady-state outputs. The proposed extremum-seeking controller includes a so-called dynamic cost function which allows for the characterization of a static input-to-output performance map, despite the presence of time-varying disturbances which induces time-varying steady-state plant outputs. We have shown that, under appropriate conditions, the extremum-seeking control scheme are uniformly ultimately bounded, and the region of convergence towards the optimal tunable plant parameters can be made arbitrarily small. An illustrative example is provided that shows the steady-state performance optimization of a closed-loop variable-gain controlled




Fig. 6. Convergence of the tunable parameter δ towards δ^* and the associated performance cost l , and the performance cost in case of two constant values of δ , associated with a low-gain and a high-gain controller.

motion system subject to a time-varying force disturbance by means of the proposed extremum-seeking control method.

REFERENCES

- [1] Krstić, M., Wang, H.-H., Stability of extremum seeking feedback for general nonlinear dynamic systems, *Automatica*, 36(4):595-601, 2000.
- [2] Teel, A.R. and Popović, D., Solving smooth and nonsmooth multivariable extremum seeking problems by the methods of nonlinear programming. *Proc. Am. Control Conf.*, pp 25-27, Arlington, 2001.
- [3] Popovic, D. and Jankovic, M. and Magner, S. and Teel, A.R., Extremum seeking methods for optimization of variable cam timing engine operation, *IEEE Trans. Control Syst. Technol.*, 14(3):398-407, 2006.
- [4] Zhang, C. and Ordóñez, R., Numerical optimization-based extremum-seeking control with application to ABS design, *IEEE Trans. Autom. control*, 52(3):454-467, 2007.
- [5] Bolder, J.J. and Witvoet, G. and de Baar, M.R. and van de Wouw, N. and Haring, M.A.M. and Westerhof, E. and Doelman, N.J. and Steinbuch, M., Robust sawtooth period control based on adaptive online optimization, *Nuclear Fusion*, 52(7), 2012.
- [6] Tan, Y. and Nešić, D. and Mareels, I., On non-local stability properties of extremum seeking control, *Automatica*, 42(6):889-903, 2006.
- [7] Höffner, K. and Hudon, N. and Guay, M., On-line feedback control for optimal periodic control systems, *The Canadian Journal of Chemical Engineering*, 85(4):479-489, 2007.
- [8] Wang, H.-H. and Krstić, M., Extremum seeking for limit cycle minimization, *IEEE Transactions on Automatic control*, 45(12):2432-2436, 2000.
- [9] Guay, M. and Dochain, D. and Perrier, M. and Hudon, N., Flatness-based extremum-seeking control over periodic orbits, *IEEE Trans. Autom. control*, 52(10):2005-2012, 2007.
- [10] Haring, M.A.M. and van de Wouw, N. and Nešić, D., Extremum-seeking control for nonlinear systems with periodic steady-state outputs, *Automatica*, 49(6):1883-1891, 2013.
- [11] Haring, M.A.M., Extremum-seeking control: convergence improvements and asymptotic stability, Ph.D. dissertation, Dept. of Engineering Cybernetics, Norwegian University of Science and Technology, Trondheim, 2016.
- [12] Heertjes, M.F. and Nijmeijer, H., Self-tuning of a switching controller for scanning motion systems, *Mechatronics*, 22(3):310-319, 2012.
- [13] Kim, K. and Kasnakoglu, C. and Serrani, A. and Samimy, M., Extremum-seeking control of subsonic cavity flow, *AIAA Journal* 47(1):195-205, 2009.
- [14] Antonello, R. and Oboe, R. and Prandi, L. and Biganzoli, F., Automatic mode matching in MEMS vibrating gyroscopes using extremum-seeking control, *IEEE Trans. Ind. Electron.*, 56(10):3880-3891, 2009.
- [15] Hunnekens, B. G. B. and Di Dino, A. and van de Wouw, N. and van Dijk, N. and Nijmeijer, H., Extremum-seeking control for the adaptive design of variable gain controllers, *IEEE Trans. Control Syst. Technol.*, 23(3):1041-1051, 2015.
- [16] Pavlov, A.V. and van de Wouw, N. and Nijmeijer, H., Uniform output regulation of nonlinear systems: a convergence dynamics approach, *Birkhäuser*, Boston, 2005.
- [17] Pavlov, A.V. and Hunnekens, B. G. B. and van de Wouw, N. and Nijmeijer, H., Steady-state performance optimization for nonlinear control systems of Lur'e type, *Automatica*, 49(7):2087-2097, 2013.
- [18] Hazeleger, L., Technical report DC2018.028, Extremum-seeking control for steady-state performance optimization of nonlinear plants with time-varying steady-state outputs, Eindhoven University of Technology, Eindhoven, The Netherlands, 2017.